

CODE



Mecklenburg County

Engineering and Building Standards Department

INTERPRETATION

Code Volume Reference: Volume II

Code Chapter Reference: 601.6 and 607.9

Subject: Water Distribution Protection

Effective Date: May 1981

Prepared/Revision Date: July 2, 2001

CODE:

601.6 Backflow Protection

607.9 Water Pressure Reducing Valve or Regulator

INTERPRETATION:

ANY water line installed to bypass a valve (i.e., backflow/pressure reducing), typically for the purpose of service, **SHALL BE PROTECTED** with an equal or greater level of protection.

Prepared by: **Consistency Team**

Approved by: _____

A handwritten signature in cursive script, reading "P. Edwards", written over a horizontal line.

Philip B. Edwards, *M/P Code Administrator*